



- NOTE:**
1. PROVIDE ADAPTORS BETWEEN DISSIMILAR PIPE MATERIALS AND SIZES TO MAKE PRESSURE TIGHT CONNECTION. MATERIALS SHALL BE BRONZE OR COPPER.
 2. PROVIDE OPTIONAL "INLET RISER" ONLY WHERE DETERMINED BY ENGINEER DURING CONSTRUCTION.
 3. 1 1/2" HDPE SERVICE LEAD SHALL BE INSTALLED WITH TRACER WIRE. REFER TO MHOG DESIGN STANDARDS FOR ADDITIONAL DETAIL.

- NOTES:**
1. WIRE CONNECTIONS TO LOAD SIDE OF WATT HOUR METER TO BE ALUMINUM OR COPPER BUT MUST MATCH EXISTING RESIDENCE TO PREVENT DISSIMILAR METAL CONNECTION WITHIN DECO. METER.
 2. USE WEATHER COMPRESSION RING IN BOX CONNECTORS. SET SCREW TYPE ARE UNACCEPTABLE.
 3. VERIFY THAT NEUTRAL CONNECTION OF ALARM AND CONTROL WIRING IS CONNECTED PROPERLY WITHIN STATION ALARM PANEL FOR CORRECT OPERATION.
 4. MHOG OPERATES AND MAINTAINS THE PUMP STATION ALARM PANEL, THE GRINDER PUMP AND PUMP CHAMBER AND THE DISCHARGE LINE FROM THE PUMP TO THE RIGHT-OF-WAY.
 5. THE LOCATION OF THE GRINDER PUMP MUST BE APPROVED BY MHOG PRIOR TO INSTALLATION. THE GRINDER PUMP MUST BE SERVICEABLE (ACCESSIBLE BY TRUCK) AND FREE FROM OBSTRUCTION.
 6. MHOG MUST BE ONSITE FOR STARTUP OF ALL NEW GRINDER PUMPS.

SIMPLEX/DUPLEX GRINDER PUMPING STATION

NO SCALE

